

Pleasant Hill School District  
Radon Testing Results

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.  
1 spike test was conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Pleasant Hill School District	District Office	Office - Middle Desk	4972559	11/6/2020	Detector kit	0.8
Pleasant Hill School District	District Office	Business Manager's Office	4970263	11/6/2020	Detector kit	1.0
Pleasant Hill School District	District Office	Copy Room	4970244	11/6/2020	Detector kit	1.0
Pleasant Hill School District	Warehouse	Faculty Office	4972271	11/6/2020	Detector kit	4.2
Pleasant Hill School District	Warehouse	Faculty Office	9627739	7/16/2021	Retest	1.3
Pleasant Hill School District	Warehouse	Faculty Office	9627745	7/16/2021	Duplicate	1.2
Pleasant Hill Elementary School	Portable Classroom	Room 23	4970271	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Portable Classroom	Room 22	4972259	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Cafeteria	Cafeteria	4970292	11/6/2020	Detector kit	1.4
Pleasant Hill Elementary School	Gym	Gym	4972583	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Gym	Gym Office	4970222	11/6/2020	Detector kit	0.3
Pleasant Hill Elementary School	Main Building	Room 1	4970286	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Room 1	4970304	11/6/2020	Duplicate	<0.3
Pleasant Hill Elementary School	Main Building	Room 2	4972332	11/6/2020	Detector kit	0.3
Pleasant Hill Elementary School	Main Building	Room 4	4972357	11/6/2020	Detector kit	0.3
Pleasant Hill Elementary School	Main Building	Commons	4970239	11/6/2020	Detector kit	0.5
Pleasant Hill Elementary School	Main Building	Room 3	4972582	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Room 5	4972433	11/6/2020	Detector kit	0.3
Pleasant Hill Elementary School	Main Building	Room 6	4972741	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Room 7	4972535	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Room 8	4972743	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Room 9	4970287	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Room 10	4970284	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Room 10	4970129	11/6/2020	Duplicate	0.3
Pleasant Hill Elementary School	Main Building	Commons	4972745	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Office	4972425	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Principle's Office	4970231	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Health Room	4970253	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Staff Lounge	4970262	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Main Building	Staff Work Room	4972585	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Library	Storage Area	4972334	11/6/2020	Detector kit	0.6
Pleasant Hill Elementary School	Library	Storage Room	4972130	11/6/2020	Detector kit	1.2
Pleasant Hill Elementary School	Library	Library	4970261	11/6/2020	Detector kit	<0.3
Pleasant Hill Elementary School	Library	Library	4970297	11/6/2020	Duplicate	<0.3
Pleasant Hill Elementary School	Library	Library Work Room	4970119	11/6/2020	Detector kit	0.4
Pleasant Hill Elementary School	Music Building	Office	4970236	11/6/2020	Detector kit	1.0
Pleasant Hill Elementary School	Music Building	Main Room	4972532	11/6/2020	Detector kit	0.3
Pleasant Hill Elementary School	Community Center	Main Room	4972435	11/6/2020	Detector kit	1.4
Pleasant Hill Elementary School	Community Center	Outreach Office	4972229	11/6/2020	Detector kit	1.0
Pleasant Hill Elementary School	Community Center	Office	4970131	11/6/2020	Detector kit	1.4
Pleasant Hill Elementary School	Community Center	Alumni Room	4972627	11/6/2020	Detector kit	3.0
Pleasant Hill Elementary School	Community Center	Alumni Room Office	4972702	11/6/2020	Detector kit	4.1
Pleasant Hill Elementary School	Community Center	Alumni Room Office	9627749	7/16/2021	Retest	1.8
Pleasant Hill Elementary School	Wrestling Room	Gym	4972143	11/6/2020	detector kit	1.4
Pleasant Hill Elementary School	Wrestling Room	Stage Area	4970310	11/6/2020	Detector kit	1.5
Pleasant Hill Elementary School	Wrestling Room	Stage Area	4970283	11/6/2020	Duplicate	1.6
Pleasant Hill Elementary School	North Gym	Boy's Team / Locker Room	4970226	11/6/2020	Detector kit	5.2
Pleasant Hill Elementary School	North Gym	Boy's Team / Locker Room	9627751	7/16/2021	Retest	<0.3
Pleasant Hill Elementary School	North Gym	Boy's Locker Room	4972264	11/6/2020	Detector kit	1.6
Pleasant Hill Elementary School	North Gym	Coach's Office	4970293	11/6/2020	Detector kit	1.5
Pleasant Hill Elementary School	North Gym	Girl's Locker Room	4972498	11/6/2020	Detector kit	1.6
Pleasant Hill Elementary School	North Gym	Gym	4972617	11/6/2020	Detector kit	0.6
Pleasant Hill High School	Office	Admin Office	4972146	11/6/2020	Detector kit	1.4
Pleasant Hill High School	Office	Office	4970266	11/6/2020	Detector kit	1.5
Pleasant Hill High School	Office	Principle's Office	4970298	11/6/2020	Detector kit	1.2
Pleasant Hill High School	Office	Front Office	4972543	11/6/2020	Detector kit	1.6
Pleasant Hill High School	Office	Nurse's Office	4972227	11/6/2020	Detector kit	0.7
Pleasant Hill High School	Office	Copy Room	4970233	11/6/2020	Detector kit	1.1
Pleasant Hill High School	Office	Staff Lounge	4970294	11/6/2020	Detector kit	1.7
Pleasant Hill High School	Office	Counselor's Office 1	4972601	11/6/2020	Detector kit	1.4
Pleasant Hill High School	Office	Counselor's Office 2	4970118	11/6/2020	Detector kit	1.2
Pleasant Hill High School	Office	Counselor's Office 3	4970234	11/6/2020	Detector kit	1.4
Pleasant Hill High School	Office	Counselor's Office 3	4970308	11/6/2020	Duplicate	<0.3
Pleasant Hill High School	New Classroom Wing	Room 1	4970289	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room 2	4972540	11/6/2020	Detector kit	0.5
Pleasant Hill High School	New Classroom Wing	Room 3	4970179	11/6/2020	Detector kit	0.5
Pleasant Hill High School	New Classroom Wing	Room 4	4970242	11/6/2020	Detector kit	<0.3

ACTION REQUIRED

ACTION REQUIRED

ACTION REQUIRED

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.  
1 spike test was conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Pleasant Hill High School	New Classroom Wing	Commons	4972719	11/6/2020	Detector kit	0.4
Pleasant Hill High School	New Classroom Wing	Room 5	4972506	11/6/2020	Detector kit	0.4
Pleasant Hill High School	New Classroom Wing	Room 6	4970250	11/6/2020	Detector kit	0.7
Pleasant Hill High School	New Classroom Wing	Room 7	4972287	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room 8	4970122	11/6/2020	Detector kit	0.7
Pleasant Hill High School	New Classroom Wing	Room 9	4972333	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room 9	4970245	11/6/2020	Duplicate	0.5
Pleasant Hill High School	New Classroom Wing	Room 10	4970225	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room S3	4970260	11/6/2020	Detector kit	0.4
Pleasant Hill High School	New Classroom Wing	Middle School Principle	4970268	11/6/2020	Detector kit	1.1
Pleasant Hill High School	New Classroom Wing	Room S5	4970279	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room S2	4970278	11/6/2020	Detector kit	0.3
Pleasant Hill High School	New Classroom Wing	Room S2-A Prep	4972300	11/6/2020	Detector kit	0.6
Pleasant Hill High School	New Classroom Wing	Room S1	4970301	11/6/2020	Detector kit	0.5
Pleasant Hill High School	New Classroom Wing	Room S4	4972754	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Psychologist's Office	4970302	11/6/2020	Detector kit	2.9
Pleasant Hill High School	New Classroom Wing	Room 20	4970229	11/6/2020	Detector kit	0.3
Pleasant Hill High School	New Classroom Wing	Room 20	4970303	11/6/2020	Duplicate	<0.3
Pleasant Hill High School	New Classroom Wing	Room 18	4970241	11/6/2020	Detector kit	0.3
Pleasant Hill High School	New Classroom Wing	Room 19	4970281	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room 16	4970230	11/6/2020	Detector kit	0.7
Pleasant Hill High School	New Classroom Wing	Room 17	4972682	11/6/2020	Detector kit	0.5
Pleasant Hill High School	New Classroom Wing	Room 14	4972744	11/6/2020	Detector kit	0.3
Pleasant Hill High School	New Classroom Wing	Room 15	4970285	11/6/2020	detector kit	0.5
Pleasant Hill High School	New Classroom Wing	Room 13	4970280	11/6/2020	detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Commons	4972439	11/6/2020	Detector kit	0.4
Pleasant Hill High School	New Classroom Wing	Room 12	4970237	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room 11	4972254	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	New Classroom Wing	Room 11	4970295	11/6/2020	Duplicate	<0.3
Pleasant Hill High School	Library	Library Office	4972199	11/6/2020	Detector kit	0.9
Pleasant Hill High School	Library	Library	4972768	11/6/2020	Detector kit	0.8
Pleasant Hill High School	Library	Library	4970264	11/6/2020	Detector kit	0.7
Pleasant Hill High School	Old South Wing	Room 21	4970258	11/6/2020	Detector kit	0.5
Pleasant Hill High School	Old South Wing	Staff Lounge	4972289	11/6/2020	Detector kit	0.7
Pleasant Hill High School	Old South Wing	Room 22	4970142	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	Old South Wing	Room 23	4972348	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	Old South Wing	Room 24 - Art	4970115	11/6/2020	Detector kit	0.6
Pleasant Hill High School	Old South Wing	Room 24 - Art	4970296	11/6/2020	Detector kit	0.4
Pleasant Hill High School	Old South Wing	Room 26 - Woodshop	4970238	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	Old South Wing	Room 26 - Woodshop	4970132	11/6/2020	Duplicate	<0.3
Pleasant Hill High School	Old South Wing	Room 26 - Woodshop	4970148	11/6/2020	Detector kit	0.3
Pleasant Hill High School	Metal Shop	Classroom	4970223	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	Metal Shop	Classroom	4970305	11/6/2020	Detector kit	0.5
Pleasant Hill High School	Old East Wing	Kitchen	4970228	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	Old East Wing	Cafeteria	4970307	11/6/2020	Detector kit	<0.3
Pleasant Hill High School	Old East Wing	Studio A	4970257	11/6/2020	Detector kit	1.6
Pleasant Hill High School	Old East Wing	Studio B	4970252	11/6/2020	Detector kit	0.8
Pleasant Hill High School	Old East Wing	Studio C	4970247	11/6/2020	Detector kit	0.7
Pleasant Hill High School	Old East Wing	Band Room	4972274	11/6/2020	Detector kit	0.5
Pleasant Hill High School	Old East Wing	Band Director's Office	4972586	11/6/2020	Detector kit	0.7
Pleasant Hill High School	Old East Wing	Band Director's Office	4970282	11/6/2020	Duplicate	1.1
Pleasant Hill High School	Old East Wing	Choir Room	4970224	11/6/2020	Detector kit	1.0
Pleasant Hill High School	Old East Wing	Choir Room Office	4972574	11/6/2020	Detector kit	0.6
Pleasant Hill High School	Old East Wing	Studio D	4970193	11/6/2020	Detector kit	1.0
Pleasant Hill High School	Old East Wing	Studio E	4970227	11/6/2020	Detector kit	1.9
Pleasant Hill High School	Old East Wing	Music Library	4972352	11/6/2020	Detector kit	1.0
Pleasant Hill High School	Main Gym	Athletic Trainer's Office	4970309	11/6/2020	Detector kit	4.1
Pleasant Hill High School	Main Gym	Athletic Trainer's Office	9627746	7/16/2021	Retest	0.6
Pleasant Hill High School	Main Gym	Athletic Trainer's Office	9627748	7/16/2021	Duplicate	0.6
Pleasant Hill High School	Main Gym	Gym	4970255	11/6/2021	Detector kit	0.6
Pleasant Hill High School	Main Gym	Girl's Locker Room	4970243	11/6/2021	Detector kit	<0.3
Pleasant Hill High School	Main Gym	Girl's Locker Rm Coach's Office	4970274	11/6/2021	Detector kit	<0.3
Pleasant Hill High School	Main Gym	Girl's Team Room	4972313	11/6/2021	Detector kit	<0.3
Pleasant Hill High School	Main Gym	Girl's Team Room	4970235	11/6/2021	Duplicate	<0.3
Pleasant Hill High School	Main Gym	Boy's Locker Room	4970288	11/6/2021	Detector kit	<0.3
Pleasant Hill High School	Main Gym	Boy's Locker Room Office	4970276	11/6/2021	Detector kit	0.4
Pleasant Hill High School	Main Gym	Boy's Team Room	4970273	11/6/2021	Detector kit	0.8

**ACTION REQUIRED**

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.  
1 spike test was conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Pleasant Hill High School	Main Gym	Weight Room	4970134	11/6/2021	Detector kit	0.4
Pleasant Hill High School	Main Gym	Gym	4970249	11/6/2021	Detector kit	<0.3